

Message Text

UNCLASSIFIED

PAGE 01 NASSAU 00930 102051Z

63

ACTION FBOE-00

INFO OCT-01 ARA-10 ISO-00 A-01 SY-05 ABF-01 /018 W

----- 121566

P R 102000Z JUN 75

FM AMEMBASSY NASSAU

TO SECSTATE WASHDC PRIORITY 6802

INFO AMEMBASSY SANTO DOMINGO

UNCLAS NASSAU 930

E. O. 11652: N/A

TAGS: ASEC ABLD

SUBJ: SECURITY REQUIREMENTS, NEW ER, CHANCERY

REF: NASSAU 831

STEVENS/GRZYBEK CONVERSATIONS AT FBO 5/21/75

STEVENS/VARROS TELECON OF 5/30/75

STATE FOR A/SY/FO/ARA AND A/FBO; SANTO DOMINGO FOR RSO

1. RSO, WHO PRESENTLY AT POST, HAS REVIEWED SECURITY REQUIREMENTS FOR NEW ER OUTLINED REFTEL AND STATUS OF CHANCERY SECURITY RECOMMENDATIONS WITH PSO AND AMBASSADOR WEISS.

2. RSO CONCURS RECOMMENDATIONS REFTEL FOR NEW ER WITH FOLLOWING ADDITIONS/EXCEPTIONS:

A) FRONT ROCK WALL SHOULD BE RAISED (OR REPLACED IF RAISING NOT POSSIBLE) TO APPROX EIGHT FEET IN HEIGHT. TOP SHOULD BE CONSTRUCTED WITH EITHER EMBEDDED BROKEN GLASS OR A SHORT GRILLWORK (EMBASSY PREFERS LATTER). THIS WOULD ELIMINATE REQUIREMENT FOR CHAIN LINK FENCE BEHIND FRONT (SOUTHERN) WALL DESCRIBED REFTEL.

B) AS PER REFTEL, GARDEN LIGHTING SHOULD BE AUGMENTED WITH PARTICULAR EMPHASIS ON LIGHTING AT EQUALLY SPACED POINTS ON FRONT WALL TO ILLUMINATE INSIDE OF WALL AT NIGHT.

D) A GATE GUARD SHOULD BE PROVIDED (EITHER DIRECT-HIRE OR UNCLASSIFIED

UNCLASSIFIED

PAGE 02 NASSAU 00930 102051Z

CONTRACT) AND BE ON DUTY 24 HOURS DAILY. IF FUNDING FOR THIS

NOT POSSIBLE, AN ELECTRIC GATE OPENER SHOULD BE INSTALLED WHICH COULD BE ACTIVATED FROM INSIDE COM VEHICLE. EITHER WOULD PRECLUDE COM FROM HAVING TO WAIT OUTSIDE FRONT GATE IN CAR WHILE DRIVER OPENS GATE.

D) RSO AND EMBASSY HAVE AGREED ON LOCATION OF GENERATOR SHED/ POLICE GUARD POST.

E) CHAIN LINK FENCE SHOULD BE INSTALLED AS PER REFTTEL EXCEPT THAT HEIGHT AT EASTERN AND WESTERN BOUNDARIES SHOULD BE TEN FEET EXCEPT WHERE SLOPING TERRAIN REQUIRES ADDITIONAL HEIGHT. INASMUCH AS EASTERN BOUNDARY OF ER IS ONLY THIRTY FEET FROM UNDEVELOPED PROPERTY OWNED BY USG, RSO RECOMMENDS FENCE BE PLACED SIXTY TO NINETY FEET INSIDE UNDEVELOPED PROPERTY TO PRECLUDE PROXIMITY ACCESS BY UNAUTHORIZED PERSONNEL.

F) GROUND FLOOR SHUTTERS WHICH CAN BE CLOSED AND LOCKED SHOULD BE PROVIDED FOR ALL WINDOWS AND DOORS ON GROUND FLOOR.

G) HOLLOW STEEL DOOR OR STEEL LINED DOOR OR SOLID WOOD DOOR SHOULD BE PLACED AT ALL OPENINGS TO THE AMBASSADOR'S BEDROOM AND BE PROVIDED WITH SECURITY LOCKS.

H) ADEQUATE SECURITY LOCKS SHOULD BE PROVIDED ON EXTERIOR DOORS AS REQUIRED.

I) AUGMENTED LIGHTING, LOCKS AND DOOR ALARM SYSTEMS SHOULD BE PROVIDED FOR ALL DOORS FOR POOL HOUSE AND GAZEBO.

J) RSO WILL REQUEST APPROPRIATE LOCKS FROM SY/T.

3. CHANCERY SECURITY IMPROVEMENTS IMPLEMENTED WITH FOLLOWING EXCEPTIONS WHICH REQUIRE FUNDING AND/OR TECHNICAL ASSISTANCE FROM DEPARTMENT.

A) MSG DESK - PLANS TO BE FORWARDED TO POST SOONEST BY SY/T.

B) BULLET-PROOF GLASS DOOR AND ELECTRONIC LATCH FOR SECOND FLOOR ENTRANCE - PROPOSAL FOR LOCAL INSTALLATION HAS BEEN FORWARDED TO SY/T.

UNCLASSIFIED

UNCLASSIFIED

PAGE 03 NASSAU 00930 102051Z

C) PROTECTIVE GRILLWORK FOR EXTERIOR WINDOWS - EMBASSY HAS SOLICITED BIDS PER SY SPECIFICATIONS AND WILL FORWARD NLT JUNE 16.

D) CLOSED-CIRCUIT TV AND AUGMENTED EXTERIOR LIGHTING - EMBASSY AWAITING CCTV EQUIPMENT AND INSTALLATION BY DEPT.

E) STAND-BY GENERATOR FOR CHANCERY - EMBASSY AWAITING DEPARTMENT'S RESPONSE RE RSO RECOMMENDATIONS FOR EMERGENCY GENERATOR, VAULTING, AND C&R AREA REVISIONS.

4. EMBASSY REQUESTS THAT SY AND FBO COORDINATE RE SECURITY RECOMMENDATIONS FOR NEW ER AS OUTLINED ABOVE AND PROVIDE NECESSARY FUNDING FOR THEIR INCLUSION PHASE II ER RENOVATIONS. EMBASSY IS SOLICITING BIDS FOR ALL EXCEPT AUTOMATIC GATE OPENER WHICH NOT AVAILABLE LOCALLY. EMBASSY ALSO REQUESTS DEPARTMENT EXPEDITE TECHNICAL ASSISTANCE AND APPROVAL FOR CHANCERY SECURITY RECOMMENDATIONS NOT YET IMPLEMENTED.
WEISS

UNCLASSIFIED

NNN

Message Attributes

Automatic Decaptioning: X
Capture Date: 01 JAN 1994
Channel Indicators: n/a
Current Classification: UNCLASSIFIED
Concepts: n/a
Control Number: n/a
Copy: SINGLE
Draft Date: 10 JUN 1975
Decaption Date: 01 JAN 1960
Decaption Note:
Disposition Action: n/a
Disposition Approved on Date:
Disposition Authority: n/a
Disposition Case Number: n/a
Disposition Comment:
Disposition Date: 01 JAN 1960
Disposition Event:
Disposition History: n/a
Disposition Reason:
Disposition Remarks:
Document Number: 1975NASSAU00930
Document Source: CORE
Document Unique ID: 00
Drafter: n/a
Enclosure: n/a
Executive Order: N/A
Errors: N/A
Film Number: D750202-0623
From: NASSAU
Handling Restrictions: n/a
Image Path:
ISecure: 1
Legacy Key: link1975/newtext/t19750665/aaaachae.tel
Line Count: 127
Locator: TEXT ON-LINE, ON MICROFILM
Office: ACTION FBOE
Original Classification: UNCLASSIFIED
Original Handling Restrictions: n/a
Original Previous Classification: n/a
Original Previous Handling Restrictions: n/a
Page Count: 3
Previous Channel Indicators: n/a
Previous Classification: n/a
Previous Handling Restrictions: n/a
Reference: 75 NASSAU 831
Review Action: RELEASED, APPROVED
Review Authority: greeneet
Review Comment: n/a
Review Content Flags:
Review Date: 02 DEC 2002
Review Event:
Review Exemptions: n/a
Review History: RELEASED <02 DEC 2002 by PhilliR0>; APPROVED <06 FEB 2004 by greeneet>
Review Markings:

Margaret P. Grafeld
Declassified/Released
US Department of State
EO Systematic Review
06 JUL 2006

Review Media Identifier:
Review Referrals: n/a
Review Release Date: n/a
Review Release Event: n/a
Review Transfer Date:
Review Withdrawn Fields: n/a
Secure: OPEN
Status: NATIVE
Subject: SECURITY REQUIREMENTS, NEW ER, CHANCERY
TAGS: ASEC, ABLD
To: STATE
Type: TE
Markings: Margaret P. Grafeld Declassified/Released US Department of State EO Systematic Review 06 JUL 2006